



STATE OF CONNECTICUT DEPARTMENT OF PUBLIC HEALTH

Dr. Katherine A. Kelley State Public Health Laboratory 395 West Street, Rocky Hill, CT

Phone: (860) 920-6500 Fax: (860) 920-6718

LABORATORY TEST REPORT

Report To **Russell S Melmed**
Chatham Health District
240 Middletown Ave.
East Hampton, CT 06424

Attention: RUSSEL MELMED

July 10, 2026

RE: Workorder: 1379657 WorkID: 196 GREAT HILL WATER 070926

Dear RUSSEL MELMED,

Enclosed are the analytical results for sample(s) received by the laboratory Thursday, July 9, 2026. The signature on this report indicates the samples were analyzed according to the laboratory's standard operating procedures.

If you have any questions concerning this report, please contact Kimberly Holmes-Talbot at (860)920-6500 or by email at Kimberly.Holmes-Talbot@ct.gov.

Kimberly Holmes-Talbot, MS

Environmental Microbiology

This electronic signature is a true representation of my hand written signature

1379657 - 26973391

REPORT OF ANALYSIS

EPA ID CT 01057



STATE OF CONNECTICUT DEPARTMENT OF PUBLIC HEALTH

Dr. Katherine A. Kelley State Public Health Laboratory 395 West Street, Rocky Hill, CT

Phone: (860) 920-6500 Fax: (860) 920-6718

FINAL REPORT

Work Order #: 1379657 (196 GREAT HILL WATER 070926)

Sample Summary

Lab ID	Sample ID	Matrix	Date Collected	Date Received	Analytes Reported
1379657001	CHD02	Drinking Water	7/9/2026 1:35:00 PM	7/9/2026 14:08	3
Micro-Water Sample					
--Submitter Info--					
Collected By:		CHATHAM HEALTH DISTRICT			
Source:		RUSSEL MELMED			
Address:		SPRING ON GREAT HILL POND			
Name of Utility:		196 GREAT HILL POND RD			
Temp:		NOYES SCHOOLD OF MUSIC			
Town:		12.6 DEG C			
Container Size:		PORTLAND			
Station #:		250 ML			
Private Well:		CHD02			
		No (N)			

1379657 - 26973391

REPORT OF ANALYSIS

EPA ID CT 01057



STATE OF CONNECTICUT DEPARTMENT OF PUBLIC HEALTH

Dr. Katherine A. Kelley State Public Health Laboratory 395 West Street, Rocky Hill, CT

Phone: (860) 920-6500 Fax: (860) 920-6718

FINAL REPORT

Work Order #: 1379657 (196 GREAT HILL WATER 070926)

Analytical Results

Lab ID: 1379657001

Date Received: 7/9/2026 14:08

Matrix: Drinking Water

Sample ID: CHD02

Date Collected: 7/9/2026 13:35

Collector: RUSSEL MELMED

Desc: SPRING ON GREAT HILL POND

--Environmental Microbiology--

Parameter	Results	Units	Report Limit	DF	Prepared	By	Analyzed	By
(SM9223B, 23rd ed, 2016)								
Total Coliform	ABSENT	/100mL	1	1	7/9/2026 14:25	AS7	7/10/2026 08:25	TR1
E. coli	ABSENT	/100mL	1	1	7/9/2026 14:25	AS7	7/10/2026 08:25	TR1
Reagent Used:	Colilert 18	/100mL		1	7/9/2026 14:25	AS7	7/10/2026 08:25	TR1

1379657 - 26973391

REPORT OF ANALYSIS

EPA ID CT 01057